

1341 North 108<sup>th</sup> East Avenue • Tulsa, OK 74116 • Tel: 918-437-8333 • Fax: 918-437-8487

CLIENT: Bonded Logic  
411 East Ray Road  
Chandler, AZ 85225

Attn: Scott Tomkinson

Test Report No:	168394-2	Date:	June 26, 2002
-----------------	----------	-------	---------------

SUBJECT: ASTM G 21 Fungus Resistance Test.

SAMPLE ID: Samples identified by the client as "UltraTouch Duct Liner Insulation" were received from the client on 6/03/02 in good condition.

PROCEDURE: The samples were evaluated in accordance with ASTM G 21-96 for fungus resistance. The following fungi was used for this test:

Aspergillus Niger  
Penicillium Pinophilum  
Chaetomium Virens  
Aureobasidium Pullulans

No revisions to this report are allowed after 90 days of the report date.

TEST DATE: 6/21/02.


RESULTS: On the following page

CONCLUSION: The samples do comply with the requirements of ASTM G 21 for fungus resistance.

CERTIFICATION: The tests reported here were conducted under the continuous direct supervision of SGS U. S. Testing Company Inc.

  
Jeff Simmons  
Dept. Manager/Product Evaluation

SIGNED FOR AND ON BEHALF OF  
SGS U.S. TESTING COMPANY INC.

  
Dale E. Holloway  
Tulsa Branch Director

Page 1 of 2

This report is issued by SGS U.S. Testing Company Inc. under its General Conditions for Testing Services, as printed on reverse side. SGS U.S. Testing's responsibility under this report is limited to proven negligence and will in no case be more than the amount of the testing fees. Except by special arrangement, samples are not retained by SGS U.S. Testing for more than 30 days. The results shown on this test report refer only to the sample(s) tested unless otherwise stated, under the conditions agreed upon. Anyone relying on this report should understand all of the details of the engagement. Neither the name, seals, marks nor insignia of SGS U.S. Testing may be used in any advertising or promotional material without the prior written approval of SGS U.S. Testing. The test report cannot be reproduced, except in full, without prior written permission of SGS U.S. Testing Company Inc.

Member of the SGS Group (Société Générale de Surveillance)



SGS U.S. Testing Company Inc.

Report No.:168394-2

Bonded Logic, Inc.

**RESULTS:**

ASTM G 21

**Ratings**

No Traces of Growth	0
Traces of Growth (less than 10%)	1
Light Growth (10 to 30%)	2
Medium Growth (30 to 60%)	3
Heavy Growth (60% to complete coverage)	4

<u>Specimen</u>	<u>Rating</u>
1	0
2	0
3	0

\*\*\*\*\*

End of Report