RATINGS CHART – GAS BOILERS

SENTRY

Natural and L.P. Propane Gas

MODEL NUMBER †	A.G.A. INPUT (Btuh)	D.O.E. CAPACITY (Btuh)	NET I=B=R RATING WATER (Btuh) *	WATER (Sq.Ft.)	EFFICIENCY (A.F.U.E.%)		DIMENSIONS-Inches				
									C-VENT DIAMETER		
					STANDING PILOT	INTERMITTENT IGNITION	A	B	INTEGRAL DRAFT DIVERTER	EXTERNAL DRAFT HOOD	D
S-34	34,000	29,000	25,000	167	80.4	84.0	8⅛	14⅝	4	_	_
S-60	60,000	51,000	44,000	293	81.6	84.4	11⅛	17⅝	4	_	_
S-90	90,000	76,000	66,000	440	82.3	84.2	14⅛	20⅝	5	_	_
S-120	120,000	101,000	88,000	587	83.0	84.1	17⅛	23⅝	6	_	_
S-150	150,000	125,000	109,000	727	82.4	83.4	20⅛	26⅝	7	_	_
SX-150	150,000	126,000	110,000	733	82.1	83.2	20⅛	26⅝	_	6	47
SX-180	180,000	151,000	131,000	873	82.1	83.1	23⅛	29⅝	_	7	48 3/16
SX-210	210,000	175,000	152,000	1013	82.0	83.1	26⅛	32⅝	_	7	48 3/16

* Net ratings are based on a piping and pick-up allowance of 1.15. Slant/Fin should be consulted before selecting a boiler for installation having unusual piping and pick-up requirements. Ratings must be reduced by 4% at 2,000 feet elevation and an additional 4% for every additional 1,000 feet elevation over 2,000 feet.

†Type of gas: after model number, specify gas by name "Natural" or "Propane".

Note: All Sentry boilers are tested and rated for capacity under the U.S. Dept. of Energy (D.O.E.) Test Procedure for boilers.

SLANT/FIN CORPORATION, Greenvale, NY 11548 • Phone: (516) 484-2600
FAX: (516) 484-5921 • *In Canada: Slant/Fin LTD/LTEE, Mississauga, Ontario*
www.slantfin.com

©Slant/Fin Corp. 2007